

# Retail Food Inspection Report

Floyd County Health Department  
Telephone (812) 948-4726

<b>Establishment Name</b> FLOYD CENTRAL HIGH SCHOOL	<b>Telephone Number</b> Est 812-542-3010 Own 812-542-4703	<b>Date of Inspection</b> 10/27/2021	<b>ID#</b>	
<b>Address</b> 6575 OLD VINCENNES RD, FLOYDS KNOBS IN 47119	<b>Purpose</b> <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Follow-up <input type="checkbox"/> Complaint <input type="checkbox"/> Pre-Operational <input type="checkbox"/> Temporary <input type="checkbox"/> HACCP <input type="checkbox"/> Other (list)	<b>Follow Up</b>	<b>Released</b>	
<b>Owner</b> NAFCS FOOD & NUTRITION SERVICES		<b>Menu Type</b> 1 __ 2 __ 3 <input checked="" type="checkbox"/> 4 __ 5 __		
<b>Owner's Address</b> 2801 GRANTLINE RD NEW ALBANY, IN 47150-				
<b>Person in Charge</b> ROBIN RICHARDSON				
<b>Responsible Person's Email</b> RRICHARDSON@NAFCS.ORG				
<b>Certified Food Handler</b> ROBIN RICHARDSON				

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"  
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRATIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
218		X		Observed ice buildup between wall and fire suppression pipe in the walkin fridge and in between the wall and floor in the walkin fridge. This wall separates the walkin fridge from the walk in freezer. Observed ice buildup around doorframe in walkin freezer that makes it more difficult for the door to close automatically.	2 weeks
431		X		Observed area on floor under dish machine and behind blast chiller in need of cleaning.	2 days

**Summary of Violations**      C   0      NC   2      R   0  

Received by (name and title printed):	Inspected by (name and title printed): Thomas Snider CFS
Received by (signature):	Inspected by (signature): <i>Thomas Snider</i>
cc:	cc: