

Retail Food Inspection Report

Floyd County Health Department
Telephone (812) 948-4726

| | | | |
|---|--|--|-------------------------------|
| Establishment Name GREENVILLE ELEMENTARY | Telephone Number Est 812-542-5504 Own 812-542-4703 | Date of Inspection 04/07/2021 | ID# |
| Address 7025 CROSS ST, NEW ALABNY IN 47150 | Purpose <input checked="" type="checkbox"/> Routine <input type="checkbox"/> Follow-up <input type="checkbox"/> Complaint <input type="checkbox"/> Pre-Operational <input type="checkbox"/> Temporary <input type="checkbox"/> HACCP <input type="checkbox"/> Other (list) | Follow Up | Released 04/17/2021 |
| Owner NAFCS FOOD & NUTRITION SERVICES | | Menu Type 1 _ 2 _ 3 <u>X</u> 4 _ 5 _ | |
| Owner's Address 2801 GRANTLINE RD NEW ALABNY, IN 47150- | | | |
| Person in Charge SHERRIE KEITHLEY | | | |
| Responsible Person's Email CKEITHLEY@NAFCS.ORG | | | |
| Certified Food Handler CHERIE KEITHLEY | | | |

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRATIVE COLUMN MARKED AS "R"

| Section # | C | NC | R | Narrative | To Be Corrected |
|-----------|---|----|---|--|-----------------|
| 218 | | X | | Observed missing seals on the bottom of the walk-in cooler and walk-in freezer doors. Missing seal has exposed a 1/2" gap under the doors and is causing the freezer to build-up ice near gap. | 4-15-21 |

Summary of Violations C 0 NC 1 R 0

| | |
|---------------------------------------|---|
| Received by (name and title printed): | Inspected by (name and title printed): Thomas Snider EHS |
| Received by (signature): | Inspected by (signature): <i>Thomas Snider</i> |
| cc: | cc: |